

Wyandanch Memorial High School

Wyandanch Union Free School District

19-45375

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
WYAN-0070	1069	Faculty Room 103	Spray Nozzle	Non-Potable	12/9/2020	75	Placarded for Non-Drinking Use Until Remediated
WYAN-0069	1069	Faculty Room 103	Kitchen Faucet (Cold)	Potable	12/9/2020	140	Removed From Service, Pending Remediation
WYAN-0042	1054A	Central Registration/Attendance Office	Kitchen Faucet (Cold)	Potable	12/9/2020	220	Removed From Service, Pending Remediation
WYAN-0011	1025A1	Girls' Locker Room Coach's Office Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	52	Placarded for Non-Drinking Use Until Remediated
WYAN-0003	1020D1	Boys' Locker Room Coach's Office Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	20	Placarded for Non-Drinking Use Until Remediated